



Connection Details

CHANNEL	TUBE COLOUR
1	DARK BLUE
2	RED
3	YELLOW
4	DARK GREEN
5	DARK BROWN
6	BLACK
7	NATURAL
8	ORANGE
9	PINK
10	GREY
11	LIGHT BROWN
12	VIOLET
13	LIGHT GREEN
14	GOLD
15	BEIGE
16	LIGHT BLUE

TUBING TO BE SECURED EVERY 2 METRES LONG .

RADIUS TURNS TO BE USED TO PREVENT TUBE KINKING .

FINAL TUBE CONNECTIONS TO ANALYSER AND INLINE FILTERS BY COMMISSIONING ENGINEER .

CONTRACTOR TO TAPE OVER TUBE ENDS TO ENSURE CLEANLINESS OF SYSTEM .

FINAL ELECTRICAL CONNECTION BY QUALIFIED ELECTRICIAN .

Title: **AT-RLM**
Refrigerant Leak Monitor
Tubing Arrangement

Drawn: JW Date: 14.05.07 © Aquilar Ltd

Weights & Measures House
 20 Barftelot Road . Horsham
 West Sussex . RH12 1DQ
 Tel: +44 (0) 1403 216 100 . Fax: +44 (0) 8707 940 320
 Aquilar Ltd . Registered in England & Wales No. 4036575
 Registered Office: Ryebrook Studios . Woodcote Skis . Epsom . Surrey KT18 7HD

