

The Relay Expander Unit provides individual low and high level leak alarm contacts for each of the 4 or 6 channels.

The images below show an AquiTron AT-G-DETECT 4 sensor, 2 alarm level refrigerant gas system (top panel) with a “Relay Expander Unit” below.

30mm conduit connectors are used to connect the two enclosures, which allows the ribbon cable to link the two circuit boards together.



Important: All information, including illustrations, is believed to be reliable. Users, however, should independently evaluate the suitability of each product for their application. Aquilar Limited makes no warranty as to the accuracy or completeness of the information, and disclaims any liability regarding its use. The only obligations of Aquilar Limited are those in the Aquilar Standard Terms and Conditions of Sale for this product, and in no case will Aquilar Limited be liable for any incidental, indirect, or consequential damages arising from the sale, resale, use or misuse of the product. Specifications are subject to change without notice. In addition, Aquilar Limited reserves the right to make changes – without notification to Buyer – to processing or materials that do not affect compliance with any applicable specification.

Aquilar is a trademark of Aquilar Limited
TraceTek is a registered trade mark of Tyco Thermal Controls LLC

Aquilar Limited
Weights & Measures House
20 Bartelot Road
Horsham
West Sussex RH12 1DQ. UK

Tel: + 44 (0) 1403 216 100
Fax: +44 (0) 8707 940 320

E-mail: info@aquilar.co.uk
www.aquilar.co.uk