

AquiTron

AT-WM

Water Monitor
Short form Instructions



**INSTALLATION
INSTRUCTIONS**



aquilar
leak detection solutions

AquiTron

AT-WM Water Monitor

Keep these instructions local to the panel, quick guide to changing settings.

SHORT FORM OPERATING INSTRUCTIONS

For NORMAL operation, the display should be as figure 1. If two water meters are connected, there will be a channel 1 and channel 2. A leak is alerted by a beeping sound and a Red LED To wake up the screen, press ok To silence the buzzer, press ok again.



NORMAL DISPLAY
Figure 1

A. TO RESET THE CONTROLLER

Move the cursor by pressing the down arrow to "CHANNEL", displaying "LEAK" press ok. The display will show "CHANGING" for a few seconds, then it will display OK The display will change to "OK" If two channels are displayed, perform the same operation for both CHANNEL 1 and CHANNEL 2 that are in alarm.

B. ADJUSTING THE LOW OR HIGH GUARDS

- Press and hold the up and down arrows simultaneously.
- The cursor will be flashing next to "HI GRD LTR" press OK
- The cursor will now be flashing over the number, using the arrows, adjust the value to your new requirement, press OK
- To change the "LO GRD LTR" value, move the cursor down, then press OK, adjust the value to your new requirement, press OK

To return to the normal display, press the left arrow.

Note: For firmware 7.2.17x

AquiTron AT-WM Water Monitor

Important: All information, including illustrations, is believed to be reliable. Users, however, should independently evaluate the suitability of each product for their application. Aquilar Limited makes no warranty as to the accuracy or completeness of the information, and disclaims any liability regarding its use. The only obligations of Aquilar Limited are those in the Aquilar Standard Terms and Conditions of Sale for this product, and in no case will Aquilar Limited be liable for any incidental, indirect, or consequential damages arising from the sale, resale, use or misuse of the product. Specifications are subject to change without notice. In addition, Aquilar Limited reserves the right to make changes – without notification to Buyer – to processing or materials that do not affect compliance with any applicable specification.

*AquiTron is a trademark of AquiTron Limited
Aquilar is a trademark of Aquilar Limited*